

July 12, 2007 **RE-ISSUED 12/1/2010**

NORWESCO, INC.  
ANASTASIA R. O'HARA  
PO BOX 439  
ST BONIFACIUS MN 55375-0439

Re: Description: SEWAGE TANKS, POLYETHYLENE  
Manufacturer: NORWESCO, INC.  
Product Name: SEPTIC, HOLDING, OR PUMP  
Model Number(s): 750 BSR (BRUISER TANK: 42397, 42398)  
(47.0 IN. L.L., 30 IN. MAX. DEPTH OF BURY; 360 G.P.D. WHEN USED AS A SEPTIC  
TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER,  
SEE STIPULATION #2212 FOR GALLONS PER INCH INFORMATION)  
Product File No: 20070186

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- The unit must be installed in accordance with the manufacturer's instructions.
- This tank must be designed to withstand the pressures to which it will be subjected.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- Before this product is installed a warning label meeting the requirement of Comm s. 84.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.
- This product is labeled with a sticker that contains the following information: 750 GALLON, along with other manufacturer's information.

July 12, 2007 **RE-ISSUED 12/1/2010**  
Product File No: 20070186

- The gallons per inch for this product are as follows:

<b>Liquid Level in inches</b>	<b>Gallons per inch</b>	<b>Liquid Level in inches</b>	<b>Gallons per inch</b>
1	3	25	415
2	7	26	433
3	22	27	451
4	38	28	469
5	55	29	487
6	73	30	505
7	91	31	523
8	109	32	541
9	127	33	558
10	145	34	575
11	163	35	592
12	181	36	609
13	199	37	625
14	217	38	641
15	235	39	657
16	253	40	671
17	271	41	686
18	289	42	699
19	307	43	713
20	325	44	725
21	343	45	736
22	361	46	747
23	379	47	750
24	397		

This approval supersedes the approval issued on 7/12/2007 under product file number 20070186.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Products Review  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@WI.GOV